

TEST ACCORDING TO EN 50530:2010/A1:2013 OVERALL EFFICIENCY OF GRID CONNECTED PHOTOVOLTAIC INVERTERS

Test Report Number : **GZES190201205401**
Tested Model..... : **Hiverter Si-70k**
Variant Model : **N/A**

APPLICANT

Name : Hitachi Hi-Rel Power Electronics Pvt. Ltd.
Address : SM 3 & 4, Sanand – II GIDC, Industrial Estate, Boll Village,
Sanand – 382 110, Gujarat, India.

TESTING LABORATORY

Name : SGS-CSTC Standards Technical Services Co., Ltd.
Guangzhou Branch
Address : 198 Kezhu Road, Science City, Economic & Technology
Development Area, Guangzhou, Guangdong, China

Conducted (tested) by..... : Michael Tong
(Project Engineer)



Reviewed & Approved by..... : Roger Hu
(Technical Reviewer)



Date of issue : **28/02/2019**
Number of pages : **33**



Important Note:

- This document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at www.sgs.com/terms_and_conditions.htm and, for electronic format documents, subject to Terms and Conditions for Electronic Documents at www.sgs.com/terms_e-document.htm. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents.
- This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. Unless otherwise stated the results shown in this test report refer only to the sample(s) tested.

Test Report Historical Revision:

| Test Report Version | Date | Resume |
|---------------------|------------|--|
| GZES1902012054PV | 28/02/2019 | This report is a first issuance for a co-license based on report number GZES190201205201 |

INDEX

| | | |
|----------|--|-----------|
| 1 | SCOPE | 4 |
| 2 | GENERAL INFORMATION | 5 |
| 2.1 | Testing Period and Climatic conditions..... | 5 |
| 2.2 | Equipment under Testing | 5 |
| 2.3 | Test Equipment List..... | 7 |
| 2.4 | Measurement Uncertainty | 7 |
| 2.5 | Definitions | 7 |
| 2.6 | Test set up of the different Standards..... | 8 |
| 3 | RESUME OF TEST RESULTS | 9 |
| 4 | TEST RESULTS | 10 |
| 4.1 | Static MPPT efficiency test..... | 10 |
| 4.2 | Dynamic MPPT efficiency test..... | 11 |
| 4.2.1 | Test sequence with ramps 10 % - 50 % PDCn | 11 |
| 4.2.2 | Test sequence with ramps 30 % - 100 % PDCn | 12 |
| 4.2.3 | Start-up and shut-down test with slow ramps..... | 13 |
| 4.3 | Static power conversion efficiency..... | 14 |
| 4.4 | Overall efficiency | 15 |
| 4.5 | European efficiency..... | 16 |
| 4.6 | CEC efficiency..... | 17 |
| 5 | PICTURES | 18 |
| 6 | ELECTRICAL SCHEMES | 33 |

EN 50530:2010/A1:2013**1 SCOPE**

SGS-CSTC Standards Technical Services Co., Ltd. Guangzhou Branch has been contract by Hitachi Hi-Rel Power Electronics Pvt. Ltd., in order to perform the testing according to following standards:

:

- **EN 50530:2010/A1:2013.** Overall efficiency of grid connected photovoltaic inverters.

2 GENERAL INFORMATION

2.1 Testing Period and Climatic conditions

The necessary testing has been performed along 6 days between the 14th of Feb. and the 20th of Feb. of 2019.

All the tests and checks have been performed in accordance with the reference Standard (the tests are done at $25 \pm 5^{\circ}\text{C}$, $96 \text{ kPa} \pm 10 \text{ kPa}$ and $50\% \text{ RH} \pm 10\% \text{ RH}$).

SITE TEST

Name : Shenzhen BALUN Technology Co., Ltd
 Address : Block B, 1st FL, Baisha Science and Technology Park, Shahe
 Xi Road, Nanshan District, Shenzhen, Guangdong Province,
 P. R. China

2.2 Equipment under Testing

Test Item

Apparatus type/ Installation : Solar Grid-tied Inverter
 Manufacturer/ Supplier/ Installer : Hitachi Hi-Rel Power Electronics Pvt. Ltd.
 Trade mark : 

Type : Hiverter
 Model : Hiverter Si-70k

Serial Number : ZJ2CS170J7A090
 Software Version : V1.10
 Rated Characteristics : DC input: 250-950V (1000V max.), Max. 40/40/40A
 AC output: 3~/PE 480Vac, 50Hz, 90A, 70000W

Date of manufacturing: 2018

Test item particulars

Input DC
 Output 3~/PE
 Class of protection against electric shock Class I
 Degree of protection against moisture IP 65
 Type of connection to the main supply Three phase – Fixed installation
 Cooling group Fans
 Modular No
 Internal Transformer No

EN 50530:2010/A1:2013

Rating Plate:

| HITACHI | |
|---|-----------------------------------|
| Solar Grid Tied Inverter | |
| Model No. | Hiverter Si-70k |
| Max. DC Input Voltage | 1000V |
| Operating MPPT Voltage Range | 250-950V |
| Max. Input Current | 40A/40A/40A |
| Max. PV Isc | 48A/48A/48A |
| Nominal Grid Voltage | 3/PE,480VAC |
| Max. Output Current | 90A |
| Nominal Grid Frequency | 50Hz/60Hz |
| Nominal Output Power | 70000W |
| Max. Output Power | 75000VA |
| Power Factor | >0.99(adjustable+/-0.8) |
| Ingress Protection | IP65 |
| Operating Temperature Range | -25 ~+60°C |
| Protective Class | Class I |
|  Hitachi Hi-Rel Power Electronics Pvt. Ltd. SM 3 & 4, Sanand - II GIDC, Industrial Estate, Bol Village, Sanand - 382 110, Gujarat, India., www.hitachi-hirel.com | |
|         | |

Model fully tested:

- Hiverter Si-70k

The results obtained apply only to the particular sample tested that is the subject of the present test report. The most unfavorable result values of the verifications and tests performed are contained herein. Throughout this report a point (e) is used as the decimal separator.

2.3 Manufacturer and Factory information

Manufacturer Name.....: **Hitachi Hi-Rel Power Electronics Pvt. Ltd.**
 Manufacturer Address: SM 3 & 4, Sanand – II GIDC, Industrial Estate, Boll Village, Sanand – 382 110, Gujarat, India.
 Factory Name: **Dongguan SOFAR SOLAR Co., Ltd.**
 Factory Address: 1F - 6F, Building E, No. 1 JinQi Road, Bihu Industrial Park, Wulian Village, Fenggang Town, Dongguan City, Guangdong Province, P.R. China.

2.4 Test Equipment List

| | No. | Equipment Name | MARK/Model No. | Equipment No. | Equipment calibration due date |
|--------------|-----|------------------------------|-------------------|----------------------|--------------------------------|
| BALUN | 1 | Heating Recoder | Agilent / 34970A | BZ-SFT-L130 | 2019/03/14 |
| | 2 | Power analyzer | HIOKI / PW6001-16 | BZ-EP-L005 | 2019/05/22 |
| | 3 | Temperature & Humidity meter | BENETECH/GM1360 | BL-SFT-L055 | 2019/03/13 |
| SGS | 4 | True RMS Multimeter | Fluke / 289C | GZE012-53 (22930028) | 2019/03/05 |

2.5 Measurement Uncertainty

| | | |
|--|-----------------------------------|--------|
| | Voltage measurement uncertainty | ±1,5 % |
| | Current measurement uncertainty | ±2,0 % |
| | Frequency measurement uncertainty | ±0,2 % |
| | Time measurement uncertainty | ±0,2 % |
| | Power measurement uncertainty | ±2,5 % |
| | Phase Angle | ±1° |
| | cosφ | ±0,01 |


Note: The measurement uncertainties associated with other parameters measured during the tests are in the laboratory at disposal of the solicitant.

2.6 Definitions

| | | | |
|----------------------|---|-------------------|---|
| EUT | Equipment Under Testing | Q _n | Nominal Reactive Power |
| I _{DC,I} | Sampled value of the inverter's input current | S _n | Nominal Apparent Power (Inverter) |
| I _n | Nominal Current (Inverter) | T _M | Overall measuring period |
| p.u | Per unit | U _{DC,I} | Sampled value of the inverter's input voltage |
| P _{DC} | Measured input power of the device under test | U _n | Nominal Voltage |
| P _{MPP,PVS} | MPP power provided by the PV simulator | ΔT | Period between two subsequent sample values |
| P _n | Nominal Active Power (Inverter) | η | Efficiency |

2.7 TEST SET UP OF THE DIFFERENT STANDARDS.

Below is the simplified construction of the test set up.



Different equipment has been used to take measures as it shows in chapter 2.3. Current and voltage clamps have been connected to the inverter output for all the tests.

All the tests described in the following pages have used this specified test setup.

The test bench used includes:

| EQUIPMENT | MARK / MODEL | RATED CHARACTERISTICS | OWNER / ID.CODE |
|----------------------|---------------------|------------------------------|------------------------|
| AC source | Kewell / KACM-75-33 | Voltage: 0-600 V 75kVA | Balun/BZ-EP-L001 |
| PV source(*) | Kewell / IVS-60KW | Voltage: 0 - 1000 V 60kW | Balun/BZ-EP-L002 |
| Programmable ac load | QUNLING / ACLT-3820 | Voltage: 0-600 V 60kVA | Balun/BZ-EP-L003 |

(*) Validation by SGS. The report of verification is in the laboratory at disposal of the requestor.

EN 50530:2010/A1:2013

3 RESUME OF TEST RESULTS

INTERPRETATION KEYS

- Test object does meet the requirement **P** Pass
- Test object does not meet the requirement **F** Fails
- Test case does not apply to the test object..... **N/A** Not applicable
- To make a reference to a table or an annex. See additional sheet
- To indicate that the test has not been realized **N/R** Not realized

| STANDARD SECTION | STANDARD REQUIREMENTS | |
|------------------|--|----------|
| | EN 50530:2010/A1:2013 | |
| 4.3 | Static MPPT efficiency | P |
| 4.3.1 | Test conditions for the Static MPPT efficiency | P |
| 4.3.2 | Measurement procedure | P |
| 4.3.3 | Evaluation – Calculation of static MPPT efficiency | P |
| 4.5 | Static power conversion efficiency | P |
| 4.5.1 | Test conditions for the static power conversion efficiency | P |
| 4.5.2 | Measurement procedure | P |
| 4.5.3 | Evaluation – Calculation of the static conversion efficiency | P |
| 5 | Calculation of the overall efficiency | P |

4 TEST RESULTS

4.1 STATIC MPPT EFFICIENCY TEST

Static MPPT efficiency test has been performed according to point 4.3 of the standard.

The MPPT efficiency describes the accuracy of an inverter to set the maximum power point on the characteristic curve of a PV generator. It is determined from the sampled instantaneous values of voltage and current at the input.

$$\eta_{MPPTstat} = \frac{1}{P_{MPP,PVS} \cdot T_M} \sum_i U_{DC,i} \cdot I_{DC,i} \cdot \Delta T$$

See point 2.5 (Definitions) of this report

The following table shows the results of this test:

| MPP voltage of the simulated I/V characteristic | Simulated I/V characteristic | MPP power of the simulated I/V characteristic normal-ised to rated DC power, $P_{MPP,PVS}/P_{DC}(\%)$ | | | | | | | |
|---|------------------------------|---|-------|-------|-------|-------|-------|-------|-------|
| | | 0.05 | 0.10 | 0.20 | 0.25 | 0.30 | 0.50 | 0.75 | 1.00 |
| U min 700 Vdc | c-Si | 99.93 | 99.96 | 99.97 | 99.98 | 99.98 | 99.98 | 99.98 | 99.98 |
| U nom 750 Vdc | | 99.93 | 99.96 | 99.98 | 99.98 | 99.98 | 99.98 | 99.99 | 99.99 |
| U max 800 Vdc | | 99.92 | 99.96 | 99.97 | 99.98 | 99.98 | 99.99 | 99.99 | 99.99 |
| U min 700 Vdc | TF | 99.94 | 99.96 | 99.98 | 99.98 | 99.98 | 99.98 | 99.98 | 99.98 |
| U nom 750 Vdc | | 99.92 | 99.96 | 99.98 | 99.98 | 99.98 | 99.98 | 99.99 | 99.99 |
| U max 800 Vdc | | 99.92 | 99.96 | 99.98 | 99.98 | 99.98 | 99.99 | 99.99 | 99.99 |

4.2 DYNAMIC MPPT EFFICIENCY TEST

Test for the dynamic MPPT efficiency are to be performed with the following sequences. The percentage specification of the radiation intensity is related to standard test conditions (STC). 100 % corresponds to 1 000 W/m² at 25 °C.

4.2.1 Test sequence with ramps 10 % - 50 % PDCn

The test has been performed according to point Annex B.2 of the standard.




Figure B.1 – Test sequence for fluctuations between small and medium irradiation intensities

| From-to W/m ² | Delta W/m ² | | | | | Waiting time setting s | |
|--------------------------|---------------------------|-----------|--------------|-----------|--------------|------------------------|----------------|
| 100-500 | 400 | | | | | 300 | |
| # Number | Slope W/m ² /s | Ramp UP s | Dwell time s | Ramp DN s | Dwell time s | Duration s | Efficiency (%) |
| 2 | 0.5 | 800 | 10 | 800 | 10 | 3540 | 99.65 |
| 2 | 1 | 400 | 10 | 400 | 10 | 1940 | 99.17 |
| 3 | 2 | 200 | 10 | 200 | 10 | 1560 | 97.49 |
| 4 | 3 | 133 | 10 | 133 | 10 | 1447 | 97.94 |
| 6 | 5 | 80 | 10 | 80 | 10 | 1300 | 97.80 |
| 8 | 7 | 57 | 10 | 57 | 10 | 1374 | 97.72 |
| 10 | 10 | 40 | 10 | 40 | 10 | 1700 | 97.72 |
| 10 | 14 | 29 | 10 | 29 | 10 | 1071 | 97.66 |
| 10 | 20 | 20 | 10 | 20 | 10 | 900 | 97.54 |
| 10 | 30 | 13 | 10 | 13 | 10 | 767 | 97.55 |
| 10 | 50 | 8 | 10 | 8 | 10 | 660 | 97.69 |

4.2.2 Test sequence with ramps 30 % - 100 % PDCn

The test has been performed according to point Annex B.3 of the standard.




Figure B.2 – Test sequence for fluctuations between medium and high irradiation intensities

| From-to W/m ² | Delta W/m ² | | | | | Waiting time setting s | |
|--------------------------|---------------------------|-----------|--------------|-----------|--------------|------------------------|----------------|
| 300-1000 | 700 | | | | | 300 | |
| # Number | Slope W/m ² /s | Ramp UP s | Dwell time s | Ramp DN s | Dwell time s | Duration s | Efficiency (%) |
| 10 | 10 | 70 | 10 | 70 | 10 | 1900 | 99.83 |
| 10 | 14 | 50 | 10 | 50 | 10 | 1500 | 99.92 |
| 10 | 20 | 35 | 10 | 35 | 10 | 1200 | 99.84 |
| 10 | 30 | 23 | 10 | 23 | 10 | 967 | 99.82 |
| 10 | 50 | 14 | 10 | 14 | 10 | 780 | 99.86 |
| 10 | 100 | 7 | 10 | 7 | 10 | 640 | 99.88 |

4.2.3 Start-up and shut-down test with slow ramps

The test has been performed according to point Annex B.4 of the standard.




Figure B.3 – Test sequence for the start-up and shut-down test of grid connected inverters

| From-to W/m² | Delta W/m² | | Dwell time setting s | | | Waiting time setting s | |
|-----------------|-----------------|--------------|----------------------------|--------------|-----------------|------------------------------|-------------------|
| 10-100 | 90 | | 30 | | | 300 | |
| # Number | Slope W/m²/s | Ramp UP s | Dwell time s | Ramp DN s | Dwell time s | Duration s | Efficiency (%) |
| 1 | 0.1 | 980 | 30 | 980 | 30 | 2320 | 96.17 |

4.3 STATIC POWER CONVERSION EFFICIENCY

Static power conversion efficiency test has been performed according to point 4.5 of the standard.

Rated output efficiency shall be calculated from measured data as follows:

$$\eta_R = (P_o / P_i) \times 100$$

where

η_R is the rated output efficiency (%);

P_o is the rated output power from power conditioner (kW);

P_i is the input power to power conditioner at rated output (kW).

The following table shows the results of this test:

| MPP voltage of the simu- lated I/V- characteristic | Simulated I/V characteristic | Power conversion efficiency(%) | | | | | | | |
|---|------------------------------------|--------------------------------|-------|-------|-------|-------|-------|-------|-------|
| | | 0.05 | 0.10 | 0.20 | 0.25 | 0.30 | 0.50 | 0.75 | 1.00 |
| U min 700 Vdc | c-Si | 97.87 | 98.38 | 98.72 | 98.76 | 98.80 | 98.78 | 98.47 | 98.36 |
| U nom 750 Vdc | | 96.89 | 98.13 | 98.50 | 98.70 | 98.74 | 98.69 | 98.39 | 98.29 |
| U max 800 Vdc | | 96.05 | 97.85 | 98.24 | 98.28 | 98.31 | 98.29 | 98.25 | 98.12 |
| U min 700 Vdc | TF | 97.93 | 98.43 | 98.74 | 98.76 | 98.80 | 98.75 | 98.50 | 98.33 |
| U nom 750 Vdc | | 97.05 | 98.17 | 98.52 | 98.72 | 98.74 | 98.71 | 98.48 | 98.29 |
| U max 800 Vdc | | 96.14 | 97.94 | 98.16 | 98.24 | 98.27 | 98.29 | 98.22 | 98.10 |

4.4 OVERALL EFFICIENCY

Overall efficiency test has been performed according to point 5 of the standard.

The overall efficiency has been calculated according the following equation:

$$\eta_t = \eta_{conv} \cdot \eta_{MPPTestat} = \frac{P_{AC}}{P_{MPP,PVS}}$$

The following table shows the results of this test:

| MPP voltage of the simulated I/V-characteristic | Simulated I/V characteristic | Overall efficiency (%) | | | | | | | |
|---|------------------------------|------------------------|-------|-------|-------|-------|-------|-------|-------|
| | | 0.05 | 0.10 | 0.20 | 0.25 | 0.30 | 0.50 | 0.75 | 1.00 |
| U min 700 Vdc | c-Si | 97.80 | 98.34 | 98.69 | 98.74 | 98.78 | 98.76 | 98.45 | 98.34 |
| U nom 750 Vdc | | 96.83 | 98.09 | 98.48 | 98.68 | 98.72 | 98.67 | 98.38 | 98.28 |
| U max 800 Vdc | | 95.98 | 97.81 | 98.21 | 98.26 | 98.29 | 98.28 | 98.24 | 98.11 |
| U min 700 Vdc | TF | 97.87 | 98.39 | 98.72 | 98.74 | 98.78 | 98.73 | 98.48 | 98.31 |
| U nom 750 Vdc | | 96.97 | 98.13 | 98.50 | 98.70 | 98.72 | 98.69 | 98.47 | 98.28 |
| U max 800 Vdc | | 96.06 | 97.90 | 98.14 | 98.22 | 98.25 | 98.28 | 98.21 | 98.09 |

4.5 EUROPEAN EFFICIENCY

European efficiency test has been performed according to point annex D.1 of the standard.

For the calculation of a weighted European MPPT and conversion efficiency the following formula and factors are to be applied:

$$\eta_{MPPTstat, EUR} = a_{EU_1} \cdot \eta_{MPP_1} + a_{EU_2} \cdot \eta_{MPP_2} + a_{EU_3} \cdot \eta_{MPP_3} + a_{EU_4} \cdot \eta_{MPP_4} + a_{EU_5} \cdot \eta_{MPP_5} + a_{EU_6} \cdot \eta_{MPP_6} \quad (D.1)$$

a_{EU_j} weighting factor

η_{MPP_j} static MPPT efficiency at partial MPP power MPP_j

Table D.1 – Weighting factors and partial MPP power levels for the calculation of the European efficiency

| | | | | | | |
|---|------------|------------|------------|------------|------------|------------|
| Weighting Factor | a_{EU_1} | a_{EU_2} | a_{EU_3} | a_{EU_4} | a_{EU_5} | a_{EU_6} |
| | 0.03 | 0.06 | 0.13 | 0.1 | 0.48 | 0.2 |
| Partial MPP power $P_{MPP, PVS} / P_{DC, r}$ | MPP_1 | MPP_2 | MPP_3 | MPP_4 | MPP_5 | MPP_6 |
| | 0.05 | 0.1 | 0.2 | 0.3 | 0.5 | 1 |

$$\eta_{MPPTstat, EUR(c-si)} = 98.41\%$$

$$\eta_{MPPTstat, EUR(TF)} = 98.41\%$$

4.6 CEC EFFICIENCY

European efficiency test has been performed according to point annex D.2 of the standard.

For the calculation of a weighted CEC MPPT and conversion efficiency the following formula and factors are to be applied:

$$\eta_{MPPTstat,CEC} = a_{CEC_1} \cdot \eta_{MPP_1} + a_{CEC_2} \cdot \eta_{MPP_2} + a_{CEC_3} \cdot \eta_{MPP_3} + a_{CEC_4} \cdot \eta_{MPP_4} + a_{CEC_5} \cdot \eta_{MPP_5} + a_{CEC_6} \cdot \eta_{MPP_6} \quad (D.2)$$

a_{CEC_i} weighting factor

η_{MPP_i} static MPPT efficiency at partial MPP power MPP_i

Table D.2 – Weighting factors and partial MPP power levels for the calculation of the CEC efficiency (California Energy Commission)

| Weighting Factor | a_{CEC_1} | a_{CEC_2} | a_{CEC_3} | a_{CEC_4} | a_{CEC_5} | a_{CEC_6} |
|--|-------------|-------------|-------------|-------------|-------------|-------------|
| | 0.04 | 0.05 | 0.12 | 0.21 | 0.53 | 0.05 |
| Partial MPP power $P_{MPP,PVS}/P_{DC,r}$ | MPP_1 | MPP_2 | MPP_3 | MPP_4 | MPP_5 | MPP_6 |
| | 0.1 | 0.2 | 0.3 | 0.5 | 0.75 | 1 |

$$\eta_{MPPTstat,CEC(c-si)} = 98.42\%$$

$$\eta_{MPPTstat,CEC(TF)} = 98.43\%$$

5 PICTURES


General view




Back view



Front view of Main board




Back view of Main board




EN 50530:2010/A1:2013

Front View of LCD board




Back View of LCD board




EN 50530:2010/A1:2013

Front View of Control board




Back View of Control board




EN 50530:2010/A1:2013

Front View of AC output board




Back View of AC output board




EN 50530:2010/A1:2013


Front View of DC input board




Back View of DC input board



Front View of Communication board




Back View of Communication board




EN 50530:2010/A1:2013


Front View of DC combine board




Back View of DC combine board




Front View of Hiverter Si-60k, Hiverter Si-70k Cap. board




Back View of Hiverter Si-60k, Hiverter Si-70k Cap. board



Front View of Hiverter Si-50k Cap. board




Back View of Hiverter Si-50k Cap. board




EN 50530:2010/A1:2013


Front View of RS232 board




Back View of RS232 board



Internal View




Connection interface




EN 50530:2010/A1:2013

AC output connection




External Eathing connection terminal



EN 50530:2010/A1:2013


Side view




Serial Number: ZJ2CS170J7A090



Software Version: V2.00



6 ELECTRICAL SCHEMES



-----END OF REPORT-----