

ATTESTATION OF CONFORMITY

Issued to: Hitachi Hi-Rel Power Electronics Pvt. Ltd.
SM 3 & 4, Sanand - II GIDC, Industrial Estate, Boll Village, Sanand - 382 110,
Gujarat, India.

For the product: Grid-connected PV Inverter

Trade name: HITACHI

Type/Model: Hiverter Si-50K

Ratings: PV input: Max.1000 Vdc, MPPT voltage range: 250-950 Vdc, MPPT full power
voltage range: 600-800 Vdc, max 40/30/30 A, Isc PV: 48/36/36 A
Output: 400V, 3N~, 50 Hz, 50000 VA, max 3x80 A

Manufactured by: Hitachi Hi-Rel Power Electronics Pvt. Ltd.
SM 3 & 4, Sanand - II GIDC, Industrial Estate, Boll Village, Sanand - 382 110,
Gujarat, India.

Requirements: EN 50530:2010+A1:2013

This Attestation is granted on account of an examination by DEKRA, the results of which are laid down in test report no. 6048244.50

The examination has been carried out on one single specimen of the product, submitted by the manufacturer.

The Attestation does not include an assessment of the manufacturer's production. Conformity of his production with the specimen tested by DEKRA is not the responsibility of DEKRA.

Shanghai, 30 January 2019

Number: 6048244.01AOC

DEKRA Testing and Certification (Shanghai) Ltd.

Kreny Lin
Certification Manager

© Integral publication of this attestation and adjoining reports is allowed

DEKRA Testing and Certification (Shanghai) Ltd.
3F #250 Jiangchangsan Road Building 16 Headquarter Economy Park Shibe Hi-Tech Park, Zhabei District Shanghai 200436 China
T +86 21 6056 7666 F +86 21 6056 7555 www.dekra-certification.com